

Annexure- C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No 3665

Dated 25/09/2026

It is certified that an inspection team headed by Smt. Dargeta Kumari

J.E

(Name of Officers with designation)

from P.H.E.D. NAWADA.

PHED

inspected the Sanskar International concept school, Daidyanathpuram
Near Sachipur Holt, Vijay Nagar Road, Kadirgaj, Nawada.

(Name & Address of the school) on 24.09.2026 (date of inspection) and on the basis

of Water Test Report Attached, bearing no 221

dated 24.09.2026 of District level Water Testing Lab. PHED Lab,
Nawada.

certified that the Sanskar International concept school,
Kadirgaj, Nawada.

(Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains

the hygienic sanitation condition in the school building & the campus as per norms

prescribed by the Central/ State/ U.T. Govt

This certificate is valid till

Signature with Seal

Name

Designation

Name & Address of the Office / Department

To Sanskar International concept
School, Kadirgaj, Nawada.

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Government of Bihar
Public Health Engineering Department
Water Quality Report

District:- Nawada

Division Name:- Public Health Engineering Division, Nawada

Sample Collected by:- **Dijeta kumar je**

Date of Sampling :- 23/09/2026

Sample Collected by:-																		Dijeta kumar/je																		Date of Sampling :- 23/09/2026																	
Sl. NO.	Block	Panchayat	Village	Ward No.	Scheme	Test Report												Source of water	Remarks																																		
						pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	ALK	F																																						
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18																																				
1	Nawada	Kadirganj	Sadipur Halt, Vijaynagar	Sanskar International Concept School Add: Baidyanathpuram, Near - Sadipur Halt, Vijaynagar Road, Kadirganj (Nawada)	Tubewell	7.5	0.8	663	431	284	72	24	45	300	0.54	Tap Water	Tested Parameters are with in permissible Limit.																																				
						Desirable Limit* (IS10500:2012)																																															
						Permissible Limit* in absence of alternate source																																															
						6.5	1.0	500	500	200	75	30	250	200	1.0																																						
						8.5	5.0	2000	2000	600	200	100	1000	600	1.5																																						

[Signature]
25.09.2026
Chemist
P.H. Division, Nawada

[Signature]
25/09/26
Assistant Engineer
P.H. Sub, Division, Nawada

[Signature]
25/09/2026
Executive Engineer
P.H. Division, Nawada